

Questions Answered: Town of Callahan, Florida Design Build Project

QUESTION:

What side of the road the utilities are on and the approximate distance from EOP for the following sections;

Mickler St. (Between 301 and Brandies)

Brandies Ave. to (Mickler St. to Amhurst Oaks Dr.)

ANSWER:

The distance to EOP from Mickler St is approximately 24,000 feet.

The distance from US301 on Mickler to Brandies Ave. is 1,102 feet.

The 6" water line is on the north side of Mickler St.

The sewer line is in the center of the roadway on Mickler St.

N. Brandies Ave. to Amhurst Oaks Dr. is approximately 3,000 feet.

Current 2" water is on the eastside of Brandies Ave to US 1.

The 6" water to Amhurst Oaks Dr. continues on east side of Martin Luther King JR. Dr. to the wastewater plant.

There is an 8" sewer force main on the west side of on Martin Luther King JR Dr. on the west side of roadway from US 1 to wastewater plant.

Amhurst Oaks Dr. to wastewater plant tie in distance approximately 2,700 feet.

Please monitor the Town website townofcallahan-fl.gov for further addendums

Questions should be addressed pwd@townofcallahan-fl.gov